

Fire performance test



For further details regarding any of the testing by Urban Hygiene Ltd, please contact:

Email: enquiries@urbanhygiene.com

Telephone: +44 (0) 1302 623193

Or visit: www.urbanhygiene.com

CERTIFICATE OF CONFORMITY

This is to confirm that easy-on has a Class 'O' fire performance rating.

Class 'O' is achieved from a combination of results achieved from testing in accordance both with BS476 Part 7 1987 and BS476 Part 6.

easy-on was tested by the Building Research Establishment on 08.05.03 and achieved a Part 6 fire propagation index, I of 5.2 and a Class 1 from Part 7. From these is it is designated Class 'O' in accordance with U.K. Building Regulations.

In addition, easy-on was further tested by London Underground Limited for toxic fumes emission (Standard 2-01001-002) as fumes are considered to be of a far greater health risk than smoke or flame in the event of a fire. In this situation, easy-on emitted trace elements only of Nitrogen and was accepted as suitable for sub surface locations, section 12 – the highest standard achievable. We note with interest that some 'competitors' products could achieve Class 'O' but could not meet the toxic fume emission standards required by LUL. Bearing in mind that the HSE report into the Kings Cross fire suggested that most deaths that occurred were due to toxic fume inhalation, we considered the fume emission test to be of the utmost importance and believe local authorities should do the same particularly in high rise developments.

We, Urban Hygiene Limited, hereby certify that this material has been made in accordance with the prescribed formulation and manufacturing procedure.

Urban Hygiene Ltd